

## Supervisory Controls

## Relative Humidity / Temperature Record

Relative Humidity / Temperature record											
File											
RELATIVE HUMIDITY & TEMPERATURE RECORD								record date : May 20, 2006			
Time	AVERAGE			T1		H1		T2		H2	
	T1	H1	T2	H2	Low	Hight	Low	Hight	Low	Hight	
0:00	25	50	26	60							
0:30	25	50	26	60							
1:00	25	50	26	60							
1:30	26	49	27	59							
2:00	26	49	27	59							
2:30	26	49	27	59							
3:00	27	48	28	58							
3:30	27	48	28	58							
4:00	27	48	28	58							
4:30	28	47	29	57							
5:00	29	46	30	56	29	29	46	46			
5:30	29	46	30	56	29	29	46	46			
6:00	29	46	30	56							
6:30	28	47	29	57							
7:00	28	47	29	57							
7:30	27	48	28	58							
8:00	27	48	28	58							
8:30	26	49	27	59							
9:00	26	49	27	59							
9:30	26	49	27	59							
10:00	25	50	26	60							
10:30	25	50	26	60							
11:00	25	50	26	60							
11:30	24	51	25	61							
12:00	24	51	25	61							
12:30	24	51	25	61							
13:00	23	52	24	62							
13:30	23	52	24	62							
14:00	23	52	24	62							
14:30	22	53	23	63							
15:00	22	53	23	63							
15:30	22	53	23	63							
16:00	21	54	22	64	21	21	54	54	64	64	
16:30	21	54	22	64	21	21	54	54	64	64	
17:00	21	54	22	64	21	21	54	54	64	64	
17:30	20	55	21	65	20	20	55	55	65	65	21
18:00	20	55	21	65	20	20	55	55	65	65	21
18:30	20	55	21	65	20	20	55	55	65	65	21

With this option, the temperature and relative humidity in one or several locations is continuously recorded. If the values are not within specifications, they are highlighted in red (over-temperature) or blue / green (under-temperature). A relay contact is provided to connect to the customer's alarm's system.

A-31740